



**AMERICAN NATIONAL STANDARDS INSTITUTE/ STEEL DECK INSTITUTE**

**ANSI/SDI AISI S906-2017 (R2024)**

**Test Standard for Determining the Load-Carrying Strength  
of Panels and Anchor-to-Panel Attachments for Roof or  
Siding Systems Tested in Accordance with ASTM E1592**



## **DISCLAIMER**

The information presented in this publication has been prepared in accordance with recognized engineering principles but is for general information only. While it is believed to be accurate, this information should not be used or relied upon for any general or specific application without a review and verification of its accuracy and applicability by a Registered/Licensed Professional Engineer, Designer or Architect. Neither the Steel Deck Institute nor the author of any information contained in this publication makes any representation or warranty, expressed or implied, respecting any of the information contained in this publication, including, but not limited to, the accuracy, completeness, or suitability of such information for any particular purpose or use and the Steel Deck Institute and each such author expressly disclaims any and all warranties, expressed or implied, regarding the information contained in this publication. By making this information available, neither the Steel Deck Institute nor any author of any information contained in this publication is rendering any professional services, and the Steel Deck Institute and/or any author of any information contained in this publication assumes no duty or responsibility with respect to any person making use of the information contained in this publication. In addition, neither the Steel Deck Institute, any of its Members or Associate Members nor the author of any information contained in this publication shall be liable for any claim, demand, injury, damage, loss, expense, cost or liability of any kind whatsoever which, directly or indirectly, in any way or manner arises out of or is connected with the use of the information contained in this publication, whether or not such claim, demand, loss, expense, or liability results directly or indirectly from any action or omission of the Steel Deck Institute, any of its Members or Associate Members or the author of any material contained in this publication. Any party using the information contained in this publication assumes all risk and liability arising from such use.

Since hazards may be associated with the handling, installation, or use of steel products, prudent construction practices should always be followed. The Steel Deck Institute recommends that parties involved in the handling, installation or use of steel construction products review all applicable manufacturers' material safety data sheets, applicable rules and regulations of the Occupational Safety and Health Administration and other government agencies having jurisdiction over such handling, installation or use, and other relevant construction practice publications.

First Printing, December 2024

Copyright © 2024 By Steel Deck Institute  
P.O. Box 70  
Florence, South Carolina 29503

*This Standard or any part thereof must not be reproduced in any form without the written permission of the Steel Deck Institute*

## PREFACE

(This Preface is not part of the ANSI/SDI AISI S906-2017 (R2024), *Test Standard for Determining the Load-Carrying Strength of Panels and Anchor-to-Panel Attachments for Roof or Siding Systems Tested in Accordance with ASTM E1592*, but is included for informational purposes only.)

This Standard is a reaffirmation of ANSI/ AISI S906-2017.

This Standard has been developed as a consensus document for the design of cold-formed steel members and structures. The intention is to provide criteria for routine use and not to provide specific criteria for infrequently encountered problems, which occur in the full range of structural design. The Symbols and Appendices to this Standard are an integral part of the Standard. A non-mandatory Commentary has been prepared to provide background for the Standard provisions and the user is encouraged to consult it. Additionally, non-mandatory User Notes may be interspersed throughout the Standard to provide concise and practical guidance in the application of the provisions. The user is cautioned that professional judgment must be exercised when data or recommendations in the Standard are applied, as described more fully in the disclaimer notice preceding this Preface.



AISI S906-17



# **AISI STANDARD**

## **Test Standard for Determining the Load-Carrying Strength of Panels and Anchor-to-Panel Attachments for Roof or Siding Systems Tested in Accordance with ASTM E1592**

2017 Edition

The material contained herein has been developed by the American Iron and Steel Institute (AISI) Committee on Specifications for the Design of Cold-Formed Steel Structural Members. The organization and the Committee have made a diligent effort to present accurate, reliable, and useful information on testing of cold-formed steel members, components or structures. The Committee acknowledges and is grateful for the contributions of the numerous researchers, engineers, and others who have contributed to the body of knowledge on the subject. With anticipated improvements in understanding of the behavior of cold-formed steel and the continuing development of new technology, this material will become dated. It is anticipated that future editions of this test procedure will update this material as new information becomes available, but this cannot be guaranteed.

The materials set forth herein are for general information only. They are not a substitute for competent professional advice. Application of this information to a specific project should be reviewed by a registered professional engineer. Indeed, in most jurisdictions, such review is required by law. Anyone making use of the information set forth herein does so at their own risk and assumes any and all resulting liability arising therefrom.

1st Printing – April 2018

Produced by American Iron and Steel Institute

Copyright American Iron and Steel Institute 2018

## **PREFACE**

The American Iron and Steel Institute Committee on Specifications developed this Standard to extend and provide methodology for the interpretation of the results of tests performed according to ASTM E1592.

The Committee acknowledges and is grateful for the contribution of the numerous engineers, researchers, producers and others who have contributed to the body of knowledge on this subject.

Commentary and User Notes are nonmandatory and copyrightable portions of this Standard.

**This Page is Intentionally Left Blank.**

**AISI Committee on Specifications for the Design  
of Cold-Formed Steel Structural Members**

R. B. Haws, <i>Chairman</i>	Nucor Buildings Group
S. R. Fox, <i>Vice-Chairman</i>	Canadian Sheet Steel Building Institute
H. H. Chen, <i>Secretary</i>	American Iron and Steel Institute
D. Allen	Super Stud Building Products
P. Bodwell	Verco Decking, Inc.
R. L. Brockenbrough	R. L. Brockenbrough and Associates
J. Buckholt	Computerized Structural Design
J. K. Crews	Unarco Material Handling, Inc.
L. R. Daudet	Simpson Strong-Tie
R. S. Douglas	National Council of Structural Engineers Associations
W. S. Easterling	Virginia Polytechnic Institute and State University
D. Fulton	Triangle Fastener Corporation
R. S. Glauz	RSG Software, Inc.
P. S. Green	Bechtel Power Corporation
W. B. Hall	University of Illinois
G. J. Hancock	University of Sydney
A. J. Harrold	BlueScope Buildings North America
L. Kruth	American Institute of Steel Construction
R. L. Madsen	Supreme Steel Framing System Association
J. A. Mattingly	Consultant
W. McRoy	ICC Evaluation Service, Inc.
C. Moen	NBM Technologies, Inc.
J. R. U. Mujagic	Structural Engineering Consultant
N. A. Rahman	The Steel Network, Inc.
G. Ralph	ClarkDietrich Building Systems
V. E. Sagan	Metal Building Manufacturers Association
T. Samiappan	OMG, Inc.
A. Sarawit	Simpson Gumpetz & Heger
B. W. Schafer	Johns Hopkins University
K. Schroeder	Devco Engineering Inc.
T. Sputo	Steel Deck Institute
R. Ziemian	Structural Stability Research Council



**Subcommittee 6 – Test-Based Design**

L. R. Daudet, <i>Chairman</i>	Simpson Strong-Tie
H. H. Chen, <i>Secretary</i>	American Iron and Steel Institute
R. S. Douglas	National Council of Structural Engineers Associations
D. Fox	TOTAL JOIST By ISPAN Systems
S. R. Fox	Canadian Sheet Steel Building Institute
W. Gould	ICC Evaluation Service, Inc.
P. S. Green	Bechtel Power Corporation
W. B. Hall	University of Illinois
R. B. Haws	Nucor Buildings Group
R. L. Madsen	Supreme Steel Framing System Association
J. R. Martin	Verco Decking, Inc.
C. Moen	NBM Technologies, Inc.
J.R.U. Mujagic	Structural Engineering Consultant
T. M. Murray	Consultant
K. Peterman	University of Massachusetts Amherst
N. A. Rahman	The Steel Network, Inc.
G. Ralph	ClarkDietrich Building Systems
V. E. Sagan	Metal Building Manufacturers Association
T. Samiappan	OMG, Inc.
B. W. Schafer	Johns Hopkins University
M. Schmeida	Gypsum Association
R. Schuster	Consultant
F. Sesma	California Expanded Metal Products
M. Speicher	NIST Engineering Laboratory
T. Sputo	Steel Deck Institute
C. Yu	University of North Texas

**AISI S906-17**  
**TEST STANDARD FOR DETERMINING THE LOAD-CARRYING STRENGTH OF**  
**PANELS AND ANCHOR-TO-PANEL ATTACHMENTS FOR ROOF OR**  
**SIDING SYSTEMS TESTED IN ACCORDANCE WITH ASTM E1592**

**1. Scope**

This procedure extends and provides methodology for the interpretation of the results of tests performed according to ASTM E1592.

**2. Referenced Documents**

The following documents or portions thereof are referenced within this Standard and shall be considered as part of the requirements of this document.

- a. American Iron and Steel Institute (AISI), Washington, DC:

S100-16, *North American Specification for the Design of Cold-Formed Steel Structural Members*

- b. ASTM International (ASTM), West Conshohocken, PA:

A370-16, *Standard Test Methods and Definitions for Mechanical Testing of Steel Products*

E6-15, *Standard Terminology Relating to Methods of Mechanical Testing*

E1592-05 (2012), *Standard Test Method for Structural Performance of Sheet Metal Roof and Siding Systems by Uniform Static Air Pressure Difference*

IEEE/ASTM SI10-10, *American National Standard for Metric Practice*

- c. Factory Mutual, Corporate Offices, Johnson, RI:

FM4471, *Approval Standard for Class 1 Panel Roofs*, 2010

**User Note:**

CEGS-07416 is listed as an optional test for roofs that were previously tested and approved:

U. S. Army Corps of Engineers, Washington, DC:

CEGS-07416, *Guide Specification for Military Construction, Structural Standing Seam Metal Roof (SSSMR) System*, 1995

**3. Terminology**

Where the following terms appear in this Standard they shall have the meaning as defined herein. Terms not defined in Section 3 of this Standard, AISI S100 or ASTM E6 shall have the ordinary accepted meaning for the context for which they are intended.

**3.1** Refer to Section 3, ASTM E1592.

**3.2** Additional or Modified Terminology

*Clip.* A single or multiple element device that frequently attaches to one edge of a panel and is fastened to the secondary structural members with one or more screws.

*Field.* Area that is not included in high-pressure edge strip conditions. For purposes of the test, a *field* condition is modeled when the *pan* distortions are independent of end and edge restraint.

*Pan.* Relatively flat portion of a panel between ribs.

*Tributary Area.* Area directly supported by the structural member between adjacent supports.

*Trim.* Sheet metal used in the finish of a building, especially around openings, and at the intersection of surfaces such as roof and walls.

*Maximum Load.* Difference in static air pressure at which failure of the specimen occurs, expressed in load per unit area. It is further defined as the point where the panel system cannot sustain additional loading.

*Unlatching Failure.* Disengagement of a panel seam or anchor that occurs in an unloaded assembly due to permanent set or distortion that occurred when the assembly was loaded. This permanent set is not always detectable from readings taken normal to the panel. It is deemed to be a serviceability limit state until a strength limit state occurs, as defined in *maximum load*.

#### **4. Summary of Test Method**

**4.1** Refer to the requirements of Section 4, ASTM E1592.

#### **5. Significance and Use**

**5.1** Refer to the requirements of Section 5, ASTM E1592.

**5.2** The end use of the procedure is the determination of load-carrying strength [factored resistance] of panels and/or their anchors under gravity or suction loading for use in a design procedure.

#### **6. Apparatus**

**6.1** Refer to the requirements of Section 6, ASTM E1592.

#### **7. Safety Precautions**

**7.1** Refer to the requirements of Section 7, ASTM E1592.

#### **8. Test Specimens**

**8.1** Refer to the requirements of Section 8, ASTM E1592.

**8.2** Edge seals shall not contain attachments that restrict deflection of the test panel in the *field* in any way. No additional structural attachments that would resist deflection of the *field* of the test panels shall be permitted.

**8.2.1** The test panel ribs shall be installed parallel to the long side of the test chamber.

##### **8.3** Number of Tests

**8.3.1** Tests shall use minimum thickness of support members (secondary structures) and maximum panel span. If results are to be interpolated for other values, the other extremes shall be tested in order to justify an interpolation procedure.

**8.3.2** Tests shall be conducted to evaluate the *field* condition.

**8.3.3** The minimum number of spans shall be as defined in Table 1.

**9. Calibration**

**9.1** Refer to the requirements of Section 9, ASTM E1592.

**10. Procedure**

**10.1** Refer to the requirements of Section 10, ASTM E1592.

**11. Test Evaluation**

**11.1** Safety factors and resistance factors shall be determined in accordance with Section I6.3.1 of AISI S100.

**11.2** If a separate test series is performed to evaluate edge conditions and the results exceed the *field* case by greater than one standard deviation, a separate design strength [factored resistance] is permitted to be established for edge conditions.

**11.3** A qualified design professional shall analyze deflections and permanent set data to ensure that deflections and permanent set are acceptable at service loads.

**Table 1**  
**Minimum Number of Equal Spans to Comply with 8.3\***

Span Length, L ft (m)	Ends With Crosswise Restraint**		
	2 end restraints	1 end restraint	No end restraints
12 ft-0 in. (3.7 m) or more	2	2	2
Below 12 ft-0 in. (3.7 m) to 8 ft-0 in. (2.4 m)	3	2	2
Below 8 ft-0 in. (2.4 m) to 6 ft-0 in. (1.8 m)	4	3	2
Below 6 ft-in. (1.8 m) to 5 ft-0 in. (1.5 m)	5	3	2
Below 5 ft-0 in. (1.5 m) to 4 ft-0 in. (1.2 m)	24/L (7.3/L)	3	3
Below 4 ft-0 in. (1.2 m) to 3 ft-4 in. (1.0 m)	24/L (7.3/L)	4	3
Below 3 ft-4 in. (1.0 m) to 3 ft-0 in. (0.9 m)	24/L (7.3/L)	4	4
Below 3 ft-0 in. (0.9 m) to 2 ft-6 in. (0.8 m)	24/L (7.3/L)	5	4
Below 2 ft-6 in. (0.8 m) to 2 ft-0 in. (0.6 m)	24/L (7.3/L)	5	5
Below 2 ft-0 in. (0.6 m)	24/L (7.3/L)	1+8/L (1+2.4/L)	10/L (3.0/L)

\* Count fractional spans as whole numbers; that is, for L=4 ft-9 in. (1.4 m), 24/4.75 =5.05 (or 7.3/1.4=5.2), use 6 spans.

\*\* L is measured in feet (when L is measured in meters, the corresponding formula in the parentheses is used).

**12. Test Report**

**12.1** Refer to the requirements of Section 11, ASTM E1592.

**12.2** Report the nominal strength [resistance] of the standing seam roof panel system as follows:

**12.2.1** For ASTM E1592, the nominal strength [resistance] shall be the ultimate load as defined by that test procedure.

**12.2.2** For FM 4471, the nominal strength [resistance] shall be the minimum uplift pressure recorded for windstorm classification achieved.

**User Note:**

For CEGS-07416, the nominal strength [resistance] is the ultimate load.

**12.3** If intermediate values are to be calculated for different spacings of anchors or secondary structures, the basis of the interpolation shall be stated in the report. If the failure modes are different on any two tests, interpolation between these two tests is permitted provided the lower bounds of the two failure modes are used.

**12.4** The design professional shall include in the report the observation as to the acceptability of deflections and permanent set data at service loads.

**AISI S906-17-C**  
**COMMENTARY ON TEST STANDARD FOR**  
**DETERMINING THE LOAD-CARRYING STRENGTH OF PANELS AND**  
**ANCHOR-TO-PANEL ATTACHMENTS FOR ROOF OR SIDING SYSTEMS TESTED**  
**IN ACCORDANCE WITH ASTM E1592**

**1. Scope**

The scope of the procedure is for testing single-skin panel systems. The procedure is based on ASTM E1592 with specific additions to define the required safety factors for a design procedure. Edge strip detail confirmation is permitted by the test method.

**2. Referenced Documents**

The standards, ASTM E1592, U. S. Army Corps of Engineers CEGS-07416, and Factory Mutual 4471 have been used in the development of this procedure. Note that the U.S. Army Corps of Engineers has replaced its roof uplift test requirement with the ASTM E1592 test, but CEGS-07416 is still listed as an optional test for roofs that were previously tested and approved.

**3. Terminology**

To promote accuracy and understanding, frequently used terms need mutual understanding. This list includes the terms from ASTM E1592 with additions and modifications.

**5. Significance and Use**

Currently, there are several organizations that have test procedures to determine product performance, but the procedures are limited to one product configuration and do not have provisions to provide the basis for a complete design procedure covering the evaluation of a safety factor for a range of product configurations. Therefore, this Standard Procedure was developed.

**6. Apparatus**

The apparatus defined in this section is specific enough to accomplish the purpose, yet broad enough to allow many facilities to perform tests. The size of the specimen is the most important criterion. Whether or not the apparatus consists of two sections with the specimen in between is not a major issue.

Measurement of rib spread has dubious value except when seam disengagement is the failure mechanism. In that case, measurements tend to substantiate the failure mechanism.

**7. Safety Precautions**

In addition to other precautions, care must be exercised in taking the deflection readings required in this procedure.

## 8. Test Specimens

The size of a test specimen has been found to be an important element in demonstrating product performance. Minimum sizes are defined, but larger sizes are allowed. It is understood that many products are offered to the marketplace that have insufficient usage to justify a large test program, yet proof of performance to some degree is required. The procedure was developed to allow a single test with a corresponding penalty due to the reduced degree of demonstrated reliability with only a single test. The procedures of Section K2.1 of AISI S100 provide for the reward/penalty relationship developed with the increasing number of tests and the associated coefficient of variation.

Minimum specimen size is as required in ASTM E1592 with the addition of the specimen configuration with both ends open. This is consistent with the 1995 edition of E1592 and is included for tests previously conducted according to that protocol. Reports from manufacturers using these test results suggest that these tests formed the basis of adequate designs. The minimum specimen length of 24 ft (7.3 m) for the condition of constraint at both ends is consistent with the requirements of FM 4471. However, in the FM tests, panels may be fastened down at all edges and it is termed a *field* test. It is the manufacturer's option to fasten the ends down or leave them open. The details of the FM test may not meet the ASTM E1592 Number of Equal Spans requirement in some cases. A purlin space of 5 ft (1.5 m) requires five spans with both ends restrained. If one end is left free, the FM test will meet ASTM E1592. The application is also different in many cases because FM tests may be run with both ends restrained, and this is used as a *field* test. Different results may be obtained when using the two variations of panel end restraints in the test procedure that are allowed by ASTM E1592.

When totaling the number ( $n$ ) of anchors tested for evaluation of  $C_p$  under Section I6.3.1 of AISI S100, it is permissible to include all fasteners with the same *tributary area* as that associated with a failed anchor instead of merely totaling the number of physical tests run on a complete assembly. When totaling the number ( $n$ ) of panels tested for evaluation of  $C_p$  under Section I6.3.1 of AISI S100, it is permissible to include all panels with the same *tributary area* as that associated with a failed panel instead of merely totaling the number of physical tests run on a complete assembly

Consideration is given to the minimum spacings and material thicknesses. If the available strength [factored resistance] developed under this procedure are intended to be used in a design procedure that encompasses different secondary structural support spacings or thinner sections for anchors to attach to, the extremes must be tested in order for interpolation to be valid. This precedent is established in AISI S908, *Base Test Method for Purlin Supporting a Standing Seam Roof System* (2017) for validating the performance of purlins braced by standing seam roof panels.

## 10. Procedure

The procedures for loading the specimen, while not complicated, need to be defined consistent with other existing and recognized standards. A significant difference between this procedure and the AISI S908 (2017) is the return to zero load after each load increment.

## 11. Test Evaluation

See Section I6.3.1 of the *Commentary* for AISI S100.


## 12. Test Report

The definition of items to be included in the report includes the typical list of failure loads and plots of load versus deformation. Of paramount importance is the calculation of the resistance factor and safety factor of design strength [factored resistance] or allowable design strength for panels and anchors. This procedure is an addition to those required in ASTM E1592-05 (2012). If interpolation is to be a part of the resulting design process, then appropriate interpolation procedure should be set forth in the report.

## References

- American Iron and Steel Institute (2016), S100-16, *North American Specification for the Design of Cold-Formed Steel Structural Members*, 2016.
- American Iron and Steel Institute (2016), S100-16-C, *Commentary on North American Specification for the Design of Cold-Formed Steel Structural Members*, 2016.
- American Iron and Steel Institute (2017), S908-17, *Base Test Method for Purlin Supporting a Standing Seam Roof System*, AISI Standards for Test Procedures, 2017.
- ASTM International (2012), E1592-05 (2012), *Standard Test Method for Structural Performance of Sheet Metal Roof and Siding Systems by Uniform Static Air Pressure Difference*, 2012.
- U. S. Army Corps of Engineers (1995), CEGS-07416 (1995), *Guide Specification for Military Construction, Structural Standing Seam Metal Roof (SSSMR) System*, July 1995.
- Factory Mutual Research (2010), "Approval Standard for Class I Panel Roofs, Class Number 4471", March 2010.





# Sci